

Project Information

For: Amarillo, Tx

Notes:

Design Information

A Weather: Amarillo Rick Husband Intl, TX, US

B Winter Design Conditions

Outside db	16 °F
Inside db	70 °F
Design TD	54 °F

C Summer Design Conditions

Outside db	98 °F
Inside db	75 °F
Design TD	23 °F
Daily range	M
Relative humidity	50 %
Moisture difference	-17 gr/lb

D Heating Summary

Structure	21056 Btuh
Ducts	8763 Btuh
Central vent (36 cfm)	1890 Btuh
Outside air	
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	31709 Btuh

E Sensible Cooling Equipment Load Sizing

Structure	13315 Btuh
Ducts	9279 Btuh
Central vent (36 cfm)	802 Btuh
Outside air	
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	23396 Btuh

G Infiltration

Method	Simplified	
Construction quality	Average	
Fireplaces	0	
	Heating	Cooling
Area (ft²)	1808	1808
Volume (ft³)	14464	14464
Air changes/hour	0.38	0.20
Equiv. AVF (cfm)	92	48

F Latent Cooling Equipment Load Sizing

Structure	119 Btuh
Ducts	48 Btuh
Central vent (36 cfm)	-361 Btuh
Outside air	
Equipment latent load	0 Btuh
Equipment Total Load (Sen+Lat)	23396 Btuh
Req. total capacity at 0.85 SHR	2.3 ton

H Heating Equipment Summary

Make	Carrier
Trade	CARRIER
Model	25HBC536A00300
AHRI ref	10508651
Efficiency	8.2 HSPF
Heating input	
Heating output	34200 Btuh @ 47°F
Temperature rise	32 °F
Actual air flow	1120 cfm
Air flow factor	0.038 cfm/Btuh
Static pressure	0.70 in H2O
Space thermostat	
Capacity balance point = 43 °F	
Backup: Carrier	
Input = 9 kW, Output = 29840 Btuh, 100 AFUE	

I Cooling Equipment Summary

Make	Carrier
Trade	CARRIER
Cond	25HBC536A00300
Coil	CNPVP3621ALA
AHRI ref	10508651
Efficiency	11.5 EER, 14 SEER
Sensible cooling	30375 Btuh
Latent cooling	2605 Btuh
Total cooling	32980 Btuh
Actual air flow	1120 cfm
Air flow factor	0.050 cfm/Btuh
Static pressure	0.70 in H2O
Load sensible heat ratio	1.00

Bold/italic values have been manually overridden

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Manual J Breakdown Series for Manual J, S, & D Building Codes Support Program

Manual S is the second step in the residential HVAC design process. The designer is responsible for following the procedures for selection and sizing residential heating and cooling appliances as there are no approved manual S software systems available.

Submittal documents must include the performance data for all proposed heating and cooling appliances. This includes the expanded performance data for the air conditioner.

Explanations for the Wrightsoft report

H. Heating Equipment Summary

<u>Make Carrier:</u>	Manufacturer
<u>Trade Carrier:</u>	Trade if different from the manufacturer
<u>Model 25HBC536A00300:</u>	Model number
<u>AHRI ref 10508651:</u>	Has been tested, listed, and will provide the stated capacities. All units should have an AHRI number
<u>Efficiency 8.2 HSPF:</u>	The efficiency of the proposed unit
<u>Heating input:</u>	No input heating for heat pumps. This would be used for gas fired appliances

Manual J Breakdown Series for Manual J, S, & D Building Codes Support Program

Heating output 34090 Btuh @ 47°F: The heating output with an outdoor temperature of 47°

Temperature rise 32° F: The software will calculate the temperature rise. This is a calculation of the output capacity and the heat CFM. The temperature rise range will be part of the manufacturer's performance data.

Actual air flow 1120 cfm: Air flow for heating. The designer will choose the proper speed from the manufacturer's performance data for the required airflow based on the temperature rise. The higher the CFM the lower the temperature rise. The lower the CFM the higher the temperature rise.

Air flow factor 0.038 cfm/Btuh: The software will calculate this factor. Based on actual airflow (cfm) and needed heating Btu's for each room.

Static pressure 0.70 in H₂O: Total external pressure used by the designer. Please refer to the duct design technical paper for more information.

Space thermostat: The designer can add some specifications for a space thermostat.

Capacity balance point = 43° The software will calculate at what point the heating appliance will have the capacity to heat the home. In this case the heat pump will not have the capacity to heat the home when the outdoor temperature is less than 43°. This is why most heat pumps will require some type of supplementary and/or back up heat. Many times, this is electric heat strips inside the air handler. This could also be a gas fired furnace

Manual J Breakdown Series for Manual J, S, & D Building Codes Support Program


Backup: Carrier

Input = 9 kW,

Output = 29840 Btuh, 100 AFUE

The software will estimate the needed backup heat. Generally, this will be close to the calculated load. The designer will typically have a set of coils that will provide supplementary heat in a stepped manner. Three steps are not unusual.

25HBC5 BALANCE POINT WORKSHEET



25HBC5

Manual J Breakdown Series for Manual J, S, & D Building Codes Support Program

I. Cooling Equipment Summary

<u>Make Carrier:</u>	The manufacturer
<u>Trade COMFORT 15 SEER2 HP:</u>	Trade if different from the manufacturer
<u>Cond 25HBC536A00300:</u>	The systems outside unit model number
<u>Coil CNPVP3621ALA:</u>	The indoor coil model number
<u>AHRI ref 10508651:</u>	The listing number that verifies the indoor and outdoor units are compatible.
<u>Efficiency 11.5 EER, 14 SEER:</u>	The systems efficiency
<u>Sensible cooling 25954 Btuh:</u>	The sensible cooling capacity of the proposed unit from the manufacturers expanded performance data
<u>Latent cooling 5316 Btuh:</u>	The latent cooling capacity of the proposed unit from the manufacturers expanded performance data
<u>Total cooling 31270 Btuh:</u>	The total cooling capacity of the proposed unit
<u>Actual air flow 1120 cfm:</u>	Airflow from the manufacturer's performance data
<u>Air flow factor 0.050 cfm/Btuh:</u>	Airflow factor is calculated by the software based on the CFM and the cooling load per room.
<u>Static pressure in 0.70 H₂O:</u>	Total external pressure used by the designer. Please refer to the duct design technical paper for more information.

Manual J Breakdown Series for Manual J, S, & D Building Codes Support Program

Load sensible heat ratio 1.0:

As discussed on the Manual J technical paper this is where the software calculates the actual sensible heat ratio.

The selection of air conditioning equipment in Texas is more complicated than in other areas of the country. First there is no calculated latent load and second is the altitude.

Below is the expanded performance data for the air conditioning equipment selected for this project. Keep in mind all the performance data we will look at are the capacities at **sea level**.

The calculated total cooling load for our example is 23,396 Btuh.

We will be using the 1350 CFM row at a 63 degree entering wet bulb. (EWB)

The 95 degree column as this is within 5 degrees of our outside summer design dry bulb.

Total capacity is 32,980 Btuh with 27,760 Btuh of that being the sensible capacity.

Total capacity of 32,980 less the Sensible capacity of 27,760 = 5,220 Latent capacity

Per Manual S one half of the excess latent capacity can be converted to sensible capacity as this is self-correcting.

$5,220 / 2 = 2,610$ New sensible capacity

$27,760 + 2,610 = 30,370$ new sensible capacity

Per Manual S we can be 15,000 Btuh oversized for air source heat pumps:

Target total load of $23,396 + 15,000 = 38,396$ Btuh < 32,980

Looks like this unit will work!

Manual J Breakdown Series for Manual J, S, & D Building Codes Support Program

DETAILED COOLING CAPACITIES# CONTINUED

EVAPORATOR AIR		CONDENSER ENTERING AIR TEMPERATURES °F (°C)											
		75 (23.9)			85 (29.4)			95 (35)		105 (40.6)			
CFM	EWB °F (°C)	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**	Capacity MBtuh		Total System KW**
		Total	Sens‡		Total	Sens‡		Total	Sens‡		Total	Sens‡	
25HBC536A**30 Outdoor Section With FX4DNF037 Indoor Section													
1050	72 (22.2)	41.59	22.07	2.25	39.75	21.35	2.51	37.77	20.58	2.79	35.67	19.78	3.11
	67 (19.4)	37.90	27.12	2.23	36.20	26.38	2.48	34.37	25.60	2.77	32.42	24.78	3.09
	63 (17.2)††	35.22	26.13	2.22	33.62	25.39	2.47	31.90	24.60	2.75	30.07	23.77	3.07
	62 (16.7)	34.53	32.04	2.21	32.97	31.27	2.47	31.31	30.44	2.75	29.55	29.53	3.07
	57 (13.9)	33.22	33.22	2.21	32.01	32.01	2.46	30.68	30.68	2.74	29.25	29.25	3.06
1200	72 (22.2)	42.40	23.16	2.28	40.49	22.43	2.54	38.44	21.66	2.83	36.24	20.84	3.15
	67 (19.4)	38.68	28.89	2.26	36.90	28.13	2.52	35.00	27.34	2.80	32.97	26.50	3.12
	63 (17.2)††	35.97	27.78	2.25	34.30	27.02	2.50	32.52	26.22	2.78	30.61	25.37	3.10
	62 (16.7)	35.34	34.38	2.24	33.74	33.54	2.50	32.07	31.86	2.78	30.45	30.45	3.10
	57 (13.9)	34.65	34.65	2.24	33.35	33.35	2.50	31.93	31.93	2.78	30.41	30.41	3.10
1350	72 (22.2)	43.03	24.20	2.31	41.06	23.46	2.58	38.93	22.68	2.86	36.68	21.85	3.18
	67 (19.4)	39.27	30.57	2.29	37.43	29.81	2.55	35.47	29.00	2.83	33.38	28.14	3.15
	63 (17.2)††	36.55	29.35	2.28	34.82	28.58	2.53	32.98	27.76	2.81	31.02	26.89	3.13
	62 (16.7)	36.05	36.44	2.28	34.51	34.51	2.53	33.01	33.01	2.81	31.41	31.41	3.14
	57 (13.9)	35.84	35.84	2.28	34.46	34.46	2.53	32.97	32.97	2.81	31.37	31.37	3.14

*If your altitude is less than or equal to 2000' above sea level, then no adjustment is needed.

Now what about the effects of altitude. Unfortunately, very few if any manufacturers provide guidance for altitude adjustment for air conditioners. Fortunately, Manual S does provide two options.

One option is to derate the capacity based on your location above sea level. Please refer to appendix 5 of the Manual S 2nd edition that provides the tables and calculation necessary for deration.

The other is to increase the CFM to maintain sea level capacity and can be found in appendix 6 manual S first edition. Air is less dense at altitude than it is at sea level, so we need to move more air to maintain the same capacity. Many designers use this method.

The formula for air density correction: $CFM \text{ at Altitude} = \text{Sea-Level Flow Rate} / \text{Density Ratio}$

Altitude Correction factors: 5000' = 0.832, 6000' = 0.801, 7000' = 0.772, 8000' = 0.743

1350 cfm / 0.832 = 1,622 cfm. In our example we would need to move a minimum of 1,622 CFM to maintain same capacity of our air conditioner at 5000' above sea level.