

# What to Look for Series Commercial HVAC Sizing Calculations

Are calculations required?  
 What are the critical design parameters?  
 Does the number of people matter?

### AHU-1 (FIRST FLOOR)

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES	
Peaked at Time: Mo/Hr: 7 / 17				Mo/Hr: 9 / 16				Mo/Hr: Heating Design				Cooling	Heating
Outside Air: OADB/WB/HR: 88 / 59 / 45				OADB: 77				OADB: 1					
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak	Coil Peak	Percent Of Total					
Btu/h	Btu/h	Btu/h		Btu/h		Btu/h	Btu/h						
<b>Envelope Loads</b>													
SkyLite Solar	0	0	0	0	0	SkyLite Solar	0	0	0.00	SADB	55.0	81.5	
SkyLite Cond	0	0	0	0	0	SkyLite Cond	0	0	0.00	Ra Plenum	75.3	68.4	
Roof Cond	0	17,671	2	0	0	Roof Cond	0	-27,163	7.04	Return	75.3	68.4	
Glass Solar	103,902	0	103,902	10	123,080	16	Glass Solar	0	0.00	Ret/OA	75.3	68.4	
Glass/Door Cond	13,416	0	13,416	1	-997	0	Glass/Door Cond	-77,556	20.11	Fn MtrTD	0.0	0.0	
Wall Cond	4,073	2,413	6,485	1	2,734	0	Wall Cond	-8,525	3.42	Fn BldTD	0.0	0.0	
Partition/Door	6,161	2,413	6,161	1	6,161	1	Partition/Door	6,835	-1.77	Fn Frict	0.0	0.0	
Floor	-10,243	0	-10,243	-1	-10,242.81	-1	Floor	-6,829	1.77				
Adjacent Floor	0.00	0.00	0.00	0.00	0.00	0.00	Adjacent Floor	0.00	0.00				
Infiltration	0	0	0	0	0	0	Infiltration	-62,784	16.28				
Sub Total ==>	117,309	20,084	137,393	14	120,716	16	Sub Total ==>	-148,858	-180.672	46.85			
<b>Internal Loads</b>													
Lights	71,165	0	71,165	7	71,165	9	Lights	0	0	0.00			
People	452,436	0	452,436	45	232,287	31	People	0	0	0.00			
Misc	313,951	0	313,951	32	313,951	41	Misc	0	0	0.00			
Sub Total ==>	837,552	0	837,552	84	617,403	81	Sub Total ==>	0	0	0.00			
Ceiling Load	3,414	-3,414	0	0	2,094	0	Ceiling Load	-10,467	0	0.00			
Ventilation Load	0	0	0	0	0	0	Ventilation Load	0	0	0.00			
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0			
Dehumid. Ov Sizing	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0.00			
Ov/Undr Sizing	19,438	0	19,438	2	21,029	3	Exhaust Heat	1,418	-0.37				
Exhaust Heat	0	0	0	0	0	0	OA Preheat Diff.	0	0.00				
Sup. Fan Heat	0	0	0	0	0	0	RA Preheat Diff.	-9,490	2.46				
Ret. Fan Heat	0	0	0	0	0	0	Additional Reheat	-196,911	51.06				
Duct Heat Pkup	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0.00				
Underflr Sup Ht Pkup	0	0	0	0	0	0	Supply Air Leakage	0	0.00				
Supply Air Leakage	0	0	0	0	0	0	Sub Total ==>						
Grand Total ==>	977,713	16,670	994,383	100.00	761,241	100.00	Grand Total ==>	-159,325	-385,655	100.00			

	Cooling	Heating
SADB	55.0	81.5
Ra Plenum	75.3	68.4
Return	75.3	68.4
Ret/OA	75.3	68.4
Fn MtrTD	0.0	0.0
Fn BldTD	0.0	0.0
Fn Frict	0.0	0.0

	Cooling	Heating
Diffuser	41,924	16,136
Terminal	41,924	16,136
Main Fan	41,924	16,135
Sec Fan	0	0
Nom Vent	0	0
AHU Vent	0	0
Infil	0	1,002
MinStop/Rh	16,135	16,135
Return	41,924	17,138
Exhaust	0	1,002
Rm Exh	0	0
Auxiliary	0	0
Leakage Dwn	0	0
Leakage Ups	0	0

	Cooling	Heating
% OA	0.0	0.0
cfm/ft²	1.74	0.67
cfm/ton	505.93	
ft³/ton	290.57	
Btu/hr-ft²	41.30	-16.14
No. People	867	

	COOLING COIL SELECTION							AREAS			HEATING COIL SELECTION			
	Total Capacity ton	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F	Leave DB/WB/HR °F	gri/b	Gross Total	Glass ft²	(%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F	
Main Clg	82.9	994.4	774.2	41,722	75.3	61.6	78.8	24,078			-388.6	16,135	55.0	81.5
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	1,402			0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	1			0.0	0	0.0	0.0
Total	82.9	994.4						1,378			-219.7	16,135	55.0	70.0
								12,493	0	0	0.0	0	0.0	0.0
								6,682	2,539	38	0.0	0	0.0	0.0
								0	0	0	0.0	0	0.0	0.0
								Ext Door			-388.6			

	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F
Main Htg	-388.6	16,135	55.0	81.5
Aux Htg	0.0	0	0.0	0.0
Preheat	0.0	0	0.0	0.0
Reheat	-219.7	16,135	55.0	70.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-388.6			

## Mechanical Load Calculations

### C103.2 Information on construction documents

- Construction documents shall be drawn to scale on suitable material.
- Electronic media documents are permitted to be submitted where approved by the code official.
- Construction documents shall be of sufficient clarity to indicate the location, nature and extent of the work proposed, and show in sufficient detail pertinent data and features of the building, systems and equipment as herein governed.
- Details shall include, but are not limited to, the following as applicable:
  5. Mechanical system design criteria

### C403.1.1 Calculation of heating and cooling loads

- Design loads associated with heating, ventilating and air conditioning of the building shall be determined in accordance with ANSI/ASHRAE/ACCA Standard 183 or by an approved equivalent computational procedure using the design parameters specified in Chapter 3.
- Heating and cooling loads shall be adjusted to account for load reductions that are achieved where energy recovery systems are utilized in the HVAC system in accordance with the ASHRAE HVAC Systems and Equipment Handbook by an approved equivalent computational procedure.

**Many of us reviewing commercial HVAC calculations are not mechanical engineers. Without a deep dive we can verify several important design parameters.**

- Summer outside design Dry Bulb and Wet Bulb Temperatures
- Winter outside design dry bulb Temperatures
- Winter and Summer inside design dry Bulb Temperatures
- Thermal Envelope Values used in the design

**Two of the common Design software programs we see are:**

- Trane Trace (Trace 700 is being phased out to Trace 3D Plus)
- Carrier HAP

Both of these programs are ANSI/ASHRAE/ACCA Standard 183 compliant.

# Plan Review Trane Trace

**Air Handling Unit**

## First Floor

Will include the area loads and design for the entire first floor

**System Checksums** is a summary of the of the loads and design parameters

## System Checksums

AHU-1 (FIRST FLOOR)

### COOLING COIL PEAK

Peaked at Time: Mo/Hr: 7 / 17  
Outside Air: OADB/WB/HR: 88 / 59 / 45

### CLG SPACE PEAK

Mo/Hr: 9 / 16  
OADB: 77

### HEATING COIL PEAK

Mo/Hr: Heating Design  
OADB: 1

## COOLING COIL PEAK

Peaked at Time: **Mo/Hr: 7 / 17** Means the highest load was in July at 5:00 pm

Outside Air: **OADB/WB/HR 88 / 59 / 45**

**OADB 88:** Outside air Dry Bulb is 88°.

This should be your adopted summer outside design

**WB 59:** Outside air Wet Bulb

This is typically around 59 degrees for Colorado

**HR 45:** Design Relative Humidity

**CLG SPACE PEAK:** Just showing the room with the largest cooling load

## HEATING COIL PEAK

**OADB 1:** Outside air Dry Bulb is 1°.

This should be your adopted winter outside design

# Plan Review

## Trane Trace

### AHU-1 (FIRST FLOOR)

#### COOLING COIL PEAK

Peaked at Time: Mo/Hr: 7 / 17  
 Outside Air: OADB/WB/HR: 88 / 59 / 45

	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat Btu/h	Net Total Btu/h
<b>Envelope Loads</b>			
Skylite Solar	0	0	0
Skylite Cond	0	0	0
Roof Cond	0	17,671	17,671
Glass Solar	103,902	0	103,902
Glass/Door Cond	13,416	0	13,416
Wall Cond	4,073	2,413	6,485
Partition/Door	6,161		6,161
Floor	-10,243		-10,243
Adjacent Floor	0.00	0.00	0.00
Infiltration	0		0
<b>Sub Total ==&gt;</b>	<b>117,309</b>	<b>20,084</b>	<b>137,393</b>
<b>Internal Loads</b>			
Lights	71,165	0	71,165
People	452,436	0	452,436
Misc	313,951	0	313,951
<b>Sub Total ==&gt;</b>	<b>837,552</b>	<b>0</b>	<b>837,552</b>
<b>Ceiling Load</b>	<b>3,414</b>	<b>-3,414</b>	<b>0</b>
<b>Ventilation Load</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Adj Air Trans Heat</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Dehumid. Ov Sizing</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Ov/Undr Sizing</b>	<b>19,438</b>	<b>0</b>	<b>19,438</b>
<b>Exhaust Heat</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Sup. Fan Heat</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Ret. Fan Heat</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Duct Heat PkUp</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Underflr Sup Ht PkUp</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Supply Air Leakage</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Grand Total ==&gt;</b>	<b>977,713</b>	<b>16,670</b>	<b>994,383</b>

If design parameters are correct the loads will be correct. Need to look for loads that are missing or not detailed.

Seems odd that an above grade story has no infiltration loads. A comments asking the designer why would be a good one

This miscellaneous load seems very high. A comment asking the designer what is included in this load would be a good one.

# Plan Review

## Trane Trace

### AHU-1 (FIRST FLOOR)

#### COOLING COIL PEAK

Peaked at Time: Mo/Hr: 7 / 17  
 Outside Air: OADB/WB/HR: 88 / 59 / 45

	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h
<b>Envelope Loads</b>			
Skylite Solar	0	0	0
Skylite Cond	0	0	0
Roof Cond	0	17,671	17,671
Glass Solar	103,902	0	103,902
Glass/Door Cond	13,416	0	13,416
Wall Cond	4,073	2,413	6,485
Partition/Door	6,161		6,161
Floor	-10,243		-10,243
Adjacent Floor	0.00	0.00	0.00
Infiltration	0		0
<b>Sub Total ==&gt;</b>	<b>117,309</b>	<b>20,084</b>	<b>137,393</b>
<b>Internal Loads</b>			
Lights	71,165	0	71,165
People	452,436	0	452,436
Misc	313,951	0	313,951
<b>Sub Total ==&gt;</b>	<b>837,552</b>	<b>0</b>	<b>837,552</b>
<b>Ceiling Load</b>	<b>3,414</b>	<b>-3,414</b>	<b>0</b>
<b>Ventilation Load</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Adj Air Trans Heat</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Dehumid. Ov Sizing</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Ov/Undr Sizing</b>	<b>19,438</b>	<b>0</b>	<b>19,438</b>
<b>Exhaust Heat</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Sup. Fan Heat</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Ret. Fan Heat</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Duct Heat Pkup</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Underflr Sup Ht Pkup</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Supply Air Leakage</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Grand Total ==&gt;</b>	<b>977,713</b>	<b>16,670</b>	<b>994,383</b>

As you can see the number of people can have a large effect on the cooling load. The number of people used in the calculation can found in the **ENGINEERING CKS** Box.

A quick calculation shows about 521 Btu's per person.  
 $452,436 / 867 = 521$

Typically we see about 250 Btu's per person.

Need to verify that the number of people (occupant load) is correct.

A good comment would be to ask why 521 Btu's per person was used.

### ENGINEERING CKS

	Cooling	Heating
% OA	0.0	0.0
cfm/ft <sup>2</sup>	1.74	0.67
cfm/ton	505.93	
ft <sup>2</sup> /ton	290.57	
Btu/hr-ft <sup>2</sup>	41.30	-16.14
No. People	867	

# Plan Review

## Trane Trace

ENGINEERING CKS		
	Cooling	Heating
% OA	0.0	0.0
cfm/ft <sup>2</sup>	1.74	0.67
cfm/ton	505.93	
ft <sup>2</sup> /ton	290.57	
Btu/hr·ft <sup>2</sup>	41.30	-16.14
No. People	867	

The other item that is a little odd is the **ft<sup>2</sup>/ton** at 290 s.f.

The square feet per ton of air conditioning is generally around 500—1000 s.f. per ton. The use of the space will also plays a part. An active space (like a gymnasium) will be on the lower side and office spaces (low activity) will be on the higher side.

A good comment would be to simply say that the s.f per ton at 290 seems low for this occupancy. Please review and comment.

# Plan Review Trane Trace

**ENTERED VALUES  
ROOM BY ROOM**

**Room Description: SECURITY**      **Zone Description: No Zone**      **System Description: PTAC**

GENERAL INFORMATION	PEOPLE	AIRFLOW INFORMATION
Floor Area: 325 ft <sup>2</sup> Fir-Fir Height: 8.0 ft Plenum Height: 0.0 ft      Height Above Fir: Slab Cnstr Type: 4" LW Concrete Room Mass: Time delay based on actual mass Ceiling R-Value: 1.766 hr-ft <sup>2</sup> -F/Btu Is There Carpet?: NO Design Cig DB / Drift Point: 75.0 °F / 75.0 °F Design Htg DB / Drift Point: 72.0 °F / 72.0 °F Design Relative Humidity: 50 % Moisture Capacitance: Medium Cig Tstat: None Htg Tstat: None Thermostat Location: Room Humidistat Location: None CO2 Sensor Location: None Room Type: Conditioned	People Type: None # of People: 1 People People Sensible: 250 Btu/h People Latent: 250 Btu/h People Schedule: Cooling Only (Design) Workstation: 1.0 workstation/person Lighting Type: Recessed fluorescent, not vented, 80% load to space Fixture Type: RECFL-NV % Load to RA: 20 % Lighting Schedule: Cooling Only (Design) Lighting Amount: 1.5 W/sq ft Ballast Factor: 1.0	<b>Cooling</b> Vent Type: None Vent Value: 0.00 cfm Vent Schedule: Available (100%) Infil Type: Neutral, Poor Const. Infil Value: 0.05 cfm/sq ft of wall Infil Schedule: Available (100%) Vav Airflow: Vav Sched: Available (100%) Supply: To be calculated Aux Supply: To be calculated Room Exhaust: Rm Exh Sched: Available (100%)
		<b>Heating</b> None 0.00 cfm Neutral, Poor Const. 0.05 cfm/sq ft of wall To be calculated To be calculated


  

Description	Area/Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft <sup>2</sup> -°F	Alpha	Type / Energy Type	Area ft <sup>2</sup>	Shade Coef	U Value Btu/h-ft <sup>2</sup> -°F	External Shading	Internal Shading	Glass					
												Adj Temp/Grnd Refl	Pct Sen/Cool Temp	Pct Rm/Heat Temp	Pct Ret/Perm Len	Rad Frc/Loss Coef	
Roof - 1	325 ft <sup>2</sup>	0	90 Steel Sheet, 8" Ins	0.0333	0.90		0			Overhang - None	None						
E	250 ft <sup>2</sup>	90	0 4" HW Block, 3" Ins	0.0877	0.90												
Opening - 1			Window			3mm Tpl Low-E Film	9	0.61	0.38	Overhang - None	None	0.00					
Misc Load 1	300.000 W		Cooling Only (Design)			None											
north	117 ft <sup>2</sup>		8" LW Conc Block	0.0877									Hourly OADB				
w	225 ft <sup>2</sup>		8" LW Conc Block	0.0877									Hourly OADB				
south	117 ft <sup>2</sup>		8" LW Conc Block	0.0877									Hourly OADB				
Floor - 1																	25 0.50

The **ENTERED VALUES ROOM BY ROOM** report gives you the thermal envelope values used in the calculation.

The bottom part of the report provides a description and U-factor values. Compare the assemblies shown in the calculation with those shown in the construction plans.

Description	Area/Amount	Dir	Const Type / Tilt Schedule	U Value Btu/h-ft <sup>2</sup> -°F	Alpha	Type / Energy Type	Area ft <sup>2</sup>	Shade Coef	U Value Btu/h-ft <sup>2</sup> -°F	External Shading	Internal Shading	Glass					
												Adj Temp/Grnd Refl	Pct Sen/Cool Temp	Pct Rm/Heat Temp	Pct Ret/Perm Len	Rad Frc/Loss Coef	
Roof - 1	325 ft <sup>2</sup>	0	90 Steel Sheet, 8" Ins	0.0333	0.90		0			Overhang - None	None						
E	250 ft <sup>2</sup>	90	0 4" HW Block, 3" Ins	0.0877	0.90												
Opening - 1			Window			3mm Tpl Low-E Film	9	0.61	0.38	Overhang - None	None						
Misc Load 1	300.000 W		Cooling Only (Design)			None											
north	117 ft <sup>2</sup>		8" LW Conc Block	0.0877									Hourly OADB				
w	225 ft <sup>2</sup>		8" LW Conc Block	0.0877									Hourly OADB				
south	117 ft <sup>2</sup>		8" LW Conc Block	0.0877									Hourly OADB				
Floor - 1																	25 0.50



# Plan Review

## Carrier HAP

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1700			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 92.2 °F / 59.8 °F			HEATING OA DB / WB -3.0 °F / -4.6 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	2800 ft <sup>2</sup>	141069	-	2800 ft <sup>2</sup>	-	-
Wall Transmission	3686 ft <sup>2</sup>	7357	-	3686 ft <sup>2</sup>	24147	-
Roof Transmission	0 ft <sup>2</sup>	0	-	0 ft <sup>2</sup>	0	-
Window Transmission	2800 ft <sup>2</sup>	15227	-	2800 ft <sup>2</sup>	85848	-
Skylight Transmission	0 ft <sup>2</sup>	0	-	0 ft <sup>2</sup>	0	-
Door Loads	0 ft <sup>2</sup>	0	-	0 ft <sup>2</sup>	0	-
Floor Transmission	17700 ft <sup>2</sup>	0	-	17700 ft <sup>2</sup>	21302	-
Partitions	0 ft <sup>2</sup>	0	-	0 ft <sup>2</sup>	0	-
Ceiling	0 ft <sup>2</sup>	0	-	0 ft <sup>2</sup>	0	-
Overhead Lighting	14514 W	45622	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	12390 W	40790	-	0	0	-
People	270	65107	72900	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	40700	0	-	0	0
Safety Factor	10% / 10%	35587	7290	10%	13130	0
>> Total Zone Loads	-	391460	80190	-	144426	0
Zone Conditioning	-	402979	80190	-	143699	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	25154 CFM	0	-	25154 CFM	0	-
Ventilation Load	6395 CFM	84408	-80193	6395 CFM	410937	0
Supply Fan Load	25154 CFM	18647	-	25154 CFM	-18647	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	2%	7829	-	2%	2889	-
>> Total System Loads	-	513863	-3	-	538877	0
Central Cooling Coil	-	513863	0	-	0	0
Central Heating Coil	-	0	-	-	538877	-
>> Total Conditioning	-	513863	0	-	538877	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

The formatting for the Carrier HAP reports is different but provides the information needed for review. The above is just one of several reports that can be requested.

