





MANUAL D FOR DESIGNERS



This document provides a simple duct design example and outlines the calculations required to determine the duct friction rate and duct size based on the required CFM.

There are several ACCA (Air Conditioning Contractors of America)–approved Manual D software programs available. However, there is no code requirement to use software for duct design. The codes simply require that you follow the Manual D design process to size ductwork properly.

ACCA provides a free Manual D speed sheet, available at:

<https://www.acca.org/viewdocument/acca-speed-sheet-for-manual-d>

Using the ACCA Manual D speed sheet is an approved method for duct design and is acceptable for submission to jurisdictions during plan review.

Before an accurate duct design can be completed, an accurate Manual J (load calculation) and Manual S (equipment selection) must be performed.

Manual D provides us with design parameters and calculations that will result in a duct system that will provide adequate air flows to rooms. Not designing your ductwork at this stage can have disastrous results like:

- Undersized ductwork affects the furnace temperature rise (to high)
- Undersized ductwork affects the cooling capacity (freezing coil)
- Equipment efficiency is lessened – more energy is used, and comfort levels go down
- Unacceptable noise levels

Manual D requires that the duct system be equipped with balancing dampers. Manual D will get you close but is not perfect. Some duct oversizing will occur; with balancing dampers the flow can be adjusted.

How many contractors use balancing dampers on their systems??

Very few, this is not horrible, but the builder may have some comfort issues.

Steps in Duct Design:

1. Determine cfm flow to each room

2. Make a rough sketch of duct runs- supplies and returns

- It is recommended to sketch directly on the framing plan to avoid structural members.


3. Collect information on the blower and all air side pressure drops This would be the coil, air filters, registers and grills

4. Determine the total equivalent length of the duct work

- This is the longest supply path plus the longest return path
- Don't forget the fittings

5. Determine the friction rate. You will need to know available static pressure for this calculation

6. Size all ductwork based on the design flow and friction rate



An accurately designed system will generally perform within these parameters:

- 1. Total system flow will be $\pm 5\%$ of design flow**
- 2. Room flows will be $\pm 10\%$ of design flow. ($\pm 20\%$ can be permitted as permitted)**
- 3. Total system static will be ± 0.10 IWC of design**
- 4. Duct velocities are within Manual D recommendations**

Recommended Velocities (FPM)								
	Supply Side				Return Side			
	Recommended		Maximum		Recommended		Maximum	
	Rigid	Flex	Rigid	Flex	Rigid	Flex	Rigid	Flex
Trunk Ducts	700	600	900	700	600	600	700	700
Branch Ducts	600	600	900	700	400	400	700	700
Supply Outlet Face Velocity	Size for throw		700		-----		-----	
Return Grille Face Velocity	-----		-----		-----		500	
Filter Grille Face Velocity	-----		-----		-----		300	

Copy of Table 3-1 from ACCA Manual D

ACCA Friction Rate Worksheet Example

(For use with explanation on the next page)

Friction Rate Worksheet

Step 1) Manufacturer's Blower Data

External static pressure (ESP) = 0.7 IWC Cfm = 600

Step 2) Component Pressure Losses (CPL)

Direct expansion refrigerant coil	<u>0.25</u>
Electric resistance heating coil	<u> </u>
Hot water coil	<u> </u>
Heat exchanger	<u> </u>
Low efficiency filter	<u> </u>
High or mid-efficiency filter	<u>0.1</u>
Electronic filter	<u> </u>
Humidifier	<u> </u>
Supply outlet	<u>0.03</u>
Return grille	<u>0.03</u>
Balancing damper	<u>0.03</u>
UV lights or other component	<u> </u>

Total component losses (CPL) 0.44 IWC

Step 3) Available Static Pressure (ASP)

ASP = (ESP - CPL) = (0.7 - 0.44) = 0.26 IWC

Step 4) Total Effective Length (TEL)

Supply-side TEL + Return-side TEL = (+) = Feet

Step 5) Friction Rate Design Value (FR)

FR value from friction rate chart = IWC/100

Understanding the Friction Rate Worksheet

The friction rate worksheet is intended to show all components in the system that restrict or inhibit airflow. Each component is represented as a friction loss measured in inches of water column.

The blower information (0.7 external static pressure and 600 CFM) comes directly from the manufacturer's blower performance chart.

The refrigerant coil friction loss also comes from manufacturer data.

It is recommended to include at least 0.1 inches of water column for the filter. Many blower charts assume a "standard" filter during testing, but these filters are often not the higher-efficiency filters used in real installations. Adding a minimum of 0.1 provides a more realistic value.

A friction loss of 0.03 inches of water column for supply registers, return grilles, and balancing dampers is a reasonable general number. Although ACCA Manual T is not required by code, it is strongly recommended to determine the actual friction loss for the specific supply registers and return grilles selected for the project.

The total component loss is the sum of all these individual losses. In this example, the total is 0.44 inches of water column.

To calculate the available static pressure, subtract the total component losses from the equipment's external static pressure rating. Using the example values:


Total external static pressure – Total component losses = Available static pressure

$$0.70 - 0.44 = 0.26 \text{ inches of water column}$$

This 0.26 inches of water column is the value used for the duct design.

Before we were able to complete our friction rate worksheet we must first calculate our total equivalent length of our duct work. This will be the longest supply duct plus the longest return duct.

EXAMPLE DUCT PLAN



We will use this sheet to identify the longest return and the longest supply ducting.


Effective Length Worksheet							
Element	Supply Run ID Number			Element	Return Run ID Number		
					R1		
Trunk Length				Trunk Length	30'		
Trunk Length				Trunk Length			
Trunk Length				Trunk Length			
Runout Length				Runout Length			
Group 1				Group 5 2*45	90'		
Group 2				Group 6	15'		
Group 3				Group 7			
Group 4				Group 8			
Group 8				Group 10			
Group 9				Group 11			
Group 11				Group 12			
Group 12				Group 13			
Group 13				Other			
Other				Other			
Total Length				Total Length	135'		

In the example duct design, we only have one return air duct system. We will start with the return system We have labeled the system R-1 and entered the linier footage of the duct system at 30'.

We need to add the equivalent length of the fittings.


Manual D contains (as does the speed sheet) all fittings and their equivalent length.

The **5H** with a H/W (Height divided by Width) ratio of 1 has an equivalent length of 45'. Yes the air thinks this fitting is 45' long. As there are two fittings = 90'



FROM MANUAL D

Square Elbow 5H	H / W	EL
	1	45
	2	30




FROM MANUAL D

The return air register fitting has an equivalent length of 15'.


This gives us a total equivalent return duct system length of 135'.

The supply duct system will use the same method. First we will enter the fittings that are common to each of the supply runs. This would be the furnace fitting **1H** H/W 0.5 and the supply boots **4G**.

FROM MANUAL D



No Vanes 1H	H / W	EL
	0.5	120
	1.0	85




Effective Length Worksheet									
Element	Supply Run ID Number				Element	Return Run ID Number			
						R1			
Trunk Length					Trunk Length	30'			
Trunk Length					Trunk Length				
Trunk Length					Trunk Length				
Runout Length					Runout Length				
Group 1	120'	120'	120'	120'	Group 5 2*45	90'			
Group 2					Group 6	15'			
Group 3					Group 7				
Group 4	80'	80'	80'	80'	Group 8				
Group 8					Group 10				
Group 9					Group 11				
Group 11					Group 12				
Group 12					Group 13				
Group 13					Other				
Other					Other				
Total Length					Total Length	135'			

Now looking at the duct design what would be your best guess on which is the longest. Typically, you would look at the three most likely and do the calculation. Before your guess look at supply runs 1 and 2.

Let's look at the duct fitting **2I**

FROM MANUAL D




EL Values		Number of Downstream Branches to End of Trunk Duct or Number of Downstream Branches to a Trunk Reducer					
Fitting		0	1	2	3	4	5 or More
	2I	65	75	85	95	100	110
	2J	50	60	65	70	75	80
	2K	50	60	65	70	75	80
	2L	70	80	90	95	105	115
	2M	70	80	90	95	105	115

In this design #1 is longer as it has one duct connection downstream. Having a trunk reduction now repressurizes the system and you start again. Supply run #2 has three runs downstream and the 2I fitting would have an equivalent length of 95'.


In this design #1 is longer as it has one duct connection downstream. Having a trunk reduction now repressurizes the system and you start again. Supply run #2 has three runs downstream and the 2I fitting would have an equivalent length of 95'.

EXAMPLE DUCT PLAN



Calculation for run #1. The trunk length is from the furnace to the top takeoff at 5'. The run out length is from the top takeoff to the supply boot. Then add the equivalent lengths for the fittings for a total of 310'. Is supply #1 the longest?

Effective Length Worksheet							
Element	Supply Run ID Number				Element	Return Run ID Number	
	1					R1	
Trunk Length	5'				Trunk Length	30'	
Trunk Length					Trunk Length		
Trunk Length					Trunk Length		
Runout Length	30'				Runout Length		
Group 1	120'	120'	120'	120'	Group 5 2*45	90'	
Group 2	75'				Group 6	15'	
Group 3					Group 7		
Group 4	80'	80'	80'	80'	Group 8		
Group 8					Group 10		
Group 9					Group 11		
Group 11					Group 12		
Group 12					Group 13		
Group 13					Other		
Other					Other		
Total Length	310'				Total Length	135'	



EL Values	A1/A2	A1/A2
Slope	2	4
1:1	10	10
2:1	5	5
4:1	5	5

FROM MANUAL D

Effective Length Worksheet							
Element	Supply Run ID Number				Element	Return Run ID Number	
	1	2	4			R1	
Trunk Length	5'	16'	26'		Trunk Length	30'	
Trunk Length					Trunk Length		
Trunk Length					Trunk Length		
Runout Length	30'	15'	25'		Runout Length		
Group 1	120'	120'	120'	120'	Group 5 2*45	90'	
Group 2	75'	95'	65'		Group 6	15'	
Group 3					Group 7		
Group 4	80'	80'	80'	80'	Group 8		
Group 8					Group 10		
Group 9					Group 11		
Group 11					Group 12		
Group 12		10'	10'		Group 13		
Group 13					Other		
Other					Other		
Total Length	310'	336'	326'		Total Length	135'	

Looks like supply #2 is the longest. Now we can finish the friction rate calculation.

Friction Rate Worksheet

Step 1) Manufacturer's Blower Data
 External static pressure (ESP) = 0.7 IWC Cfm = 600

Step 2) Component Pressure Losses (CPL)


Direct expansion refrigerant coil	<u>0.25</u>
Electric resistance heating coil	_____
Hot water coil	_____
Heat exchanger	_____
Low efficiency filter	_____
High or mid-efficiency filter	<u>0.1</u>
Electronic filter	_____
Humidifier	_____
Supply outlet	<u>0.03</u>
Return grille	<u>0.03</u>
Balancing damper	<u>0.03</u>
UV lights or other component	_____
Total component losses (CPL)	<u>0.44</u> IWC

Step 3) Available Static Pressure (ASP)
 ASP = (ESP - CPL) = (0.7 - 0.44) = 0.26 IWC

Step 4) Total Effective Length (TEL)
 Supply-side TEL + Return-side TEL = (336 + 135) = 471 Feet
0.26 * 100/471 = 0.05

Step 5) Friction Rate Design Value (FR)
 FR value from friction rate chart = 0.05 IWC/100

Friction Rate Chart




Per Manual D the friction below **0.06** and above **0.18** will result in a duct system that will not perform properly.

The example design **will not work**.

What one fitting could be changed and result in a correct friction rate?

If we were to change the furnace fitting from the 1H to a 1I that would reduce the total equivalents length by 100'. We realize that turning vanes is not something you typically see in homes...but they do exist.




With Vanes 1I	EL = 20
------------------	---------

FROM MANUAL D

Now the friction rate math is: $0.26 * 100/371 = 0.07$ Passes!!

With the friction rate now known for that system we can use the ACCA DuctWheel to size the ductwork. App Available at:

<https://apps.apple.com/us/app/acca-ductwheel/id424430207>



Example for required cfm for each room

The required cfm to each room is relative to the rooms calculated load. Essentially if the room requires 5% of the equipment's capacity the room will need 5% of the blower cfm.

To determine the required cfm per room you must calculate the heating and cooling factors.

(Wrightsoft labels this as 'Air Flow Factor')

- Heating Factor = Blower Cfm/MJ8 Heat Loss (for structure)
- Cooling Factor = Blower Cfm/MJ8 Sensible Load (for structure)
-

Solve for today's house

Heating Factor = $830 / 26,853 = .031$ * the rooms heat loss = required cfm

Cooling Factor = $995 / 14,954 = .067$ * the rooms heat gain = required cfm

Design Information			
Weather: Denver, CO, US			
Winter Design Conditions		Summer Design Conditions	
Outside db	-3 °F	Outside db	90 °F
Inside db	70 °F	Inside db	75 °F
Design TD	73 °F	Design TD	15 °F
		Daily range	H
		Relative humidity	50 %
		Moisture difference	-36 gr/lb
Heating Summary		Sensible Cooling Equipment Load Sizing	
Structure	26853 Btuh	Structure	14954 Btuh
Ducts	0 Btuh	Ducts	0 Btuh
Central vent (64 cfm)	4213 Btuh	Central vent (64 cfm)	877 Btuh
Humidification	0 Btuh	Blower	0 Btuh
Piping	0 Btuh		
Equipment load	31066 Btuh	Use manufacturer's data	y
		Rate/swing multiplier	1.00
		Equipment sensible load	15832 Btuh
Infiltration		Latent Cooling Equipment Load Sizing	
Method	Simplified		
Construction quality	Average	Structure	274 Btuh
Fireplaces	0	Ducts	0 Btuh
		Central vent (64 cfm)	-1281 Btuh
		Equipment latent load	0 Btuh
Area (ft²)	Heating 3600		
Volume (ft³)	14464	Equipment total load	15832 Btuh
Air changes/hour	0.28	Req. total capacity at 0.85 SHR	1.6 ton
Equiv. AVF (cfm)	67		
	Cooling 3600		
	14464		
	0.15		
	36		
Heating Equipment Summary		Cooling Equipment Summary	
Make	Carrier	Make	Carrier
Trade	Carrier	Trade	BASE 13 PURON AC
Model	58MCB040-12x	Cond	24ABB324(A,W)31
AHRI ref no.	144278	Coil	CAP**2414A**++TDR
		AHRI ref no.	3250356
Efficiency	92.1 AFUE	Efficiency	11.0 EER, 13 SEER
Heating input	40000 Btuh	Sensible cooling	18835 Btuh
Heating output	33156 Btuh	Latent cooling	2765 Btuh
Temperature rise	44 °F	Total cooling	21600 Btuh
Actual air flow	830 cfm	Actual air flow	995 cfm
Air flow factor	0.031 cfm/Btuh	Air flow factor	0.067 cfm/Btuh
Static pressure	0.70 in H2O	Static pressure	0.70 in H2O
Space thermostat		Load sensible heat ratio	1.00